

APPLICATION COPY

FIRE CERTIFICATE APPLICATION

- ☐ Class A Building
- ☐ Class B Building
- ☐ Class C Building

ADDRESS OF SITE

STREET _____ PARISH _____ POSTCODE _____

ADDITIONS ☐ ALTERATIONS ☐ CHANGE OF USE ☐ NEW CONSTRUCTION ☐ DEMOLITION ☐ OTHER ☐ _____

USE GROUP	CONSTRUCTION TYPE	SITE AREA	(sq ft)
-----------	-------------------	-----------	---------

EXISTING SITE COVERAGE	ADDITIONAL SITE COVERAGE	TOTAL SITE COVERAGE	(sq
------------------------	--------------------------	---------------------	-----

EXISTING FLOOR AREA	ADDITIONAL FLOOR AREA	TOTAL FLOOR AREA	(sq
---------------------	-----------------------	------------------	-----

ARE ANY OTHER PERMITS ACTIVE AT THE PROPERTY? _____ IF YES, LIST NO'S _____

APPLICANTS (OWNER'S) NAME _____

ADDRESS _____

PHONE _____ (H) _____ (W) EMAIL _____ POST CODE _____

AGENT'S NAME _____

ADDRESS _____

PHONE _____ EMAIL _____ POST CODE _____

Enclosed are 4 sets of Bound Constructions documents each consisting of _____ pages of drawings numbered _____ and dated _____
(please ensure that all drawings submitted for permit are marked "for permit" and are stamped and signed by the local registered engineers where applicable.)

*APPLICANT'S SIGNATURE _____ DATE _____

Pursuant to the Fire Safety Act 2014, I hereby apply for Fire Certificate for the project described. I request that my certificate if granted list any additional requirements which are not shown on my documents and hereby consent to any such requirements, and agree to fully comply. I further certify that I will perform no work on the property not specifically described in the application, and grant officials the right to enter onto the property to inspect the premise.

DOCUMENTS APPROVED

BY _____ DATE _____
PLANS EXAMINER

Conditions: All of the certificate conditions on the back of this page plus the following:

INSPECTION COMPLETED

BY _____ DATE _____
FIRE INSPECTOR

DATE OF CERTIFICATE ISSUE _____

SIGNATURE OF RECIPIENT _____

Exit Signs

Exit signs with not less than 6” green block letters and principle strokes 3/4” wide shall be provided over all exits.

Fire Alarm System

The fire alarm system shall be installed in accordance with:

- a. NFPA 70 - National Electrical Code
- b. NFPA 72 – National Fire Alarm and Signaling Code.

Sprinkler System and Fire Pump

The Sprinkler System and Fire pump installation shall be in accordance with:

- a. NFPA 13 – Installation of Sprinkler Systems
- b. NFPA 13R – Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies
- c. NFPA 13D - Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings
- d. NFPA 14 – Installation of Standpipes and Hose Systems
- e. NFPA 20 – Installation of Stationary Pumps
- f. NFPA 25 – Inspection, Testing and Maintenance of Water Based Fire Protection Systems.

All Engineered sprinkler systems shall be stamped by a local Registered Engineer.

Electrical Wiring Installation

All electrical wiring and equipment installed shall be in accordance with NFPA 70 - National Electrical Code.

Heating, Ventilation and Air Conditioning

The air conditioning, ventilation or heating ducts etc. shall be installed in accordance with:

- a. NFPA 90A – Standard for the Installation of Air-Conditioning and Ventilating Systems
- b. NFPA 90B – Standard for the Installation of Warm Air Heating and Air-Conditioning Systems

Commercial Cooking Equipment

The design, installation, operation, inspection, and maintenance of all public and private cooking operations shall be in accordance with NFPA 96 – Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

LPG Installation

The LPG installations and cylinders shall be in accordance with NFPA 58 – Liquid Petroleum Gas Code.

Fixed Fire Suppression System

The installation, maintenance and testing of Fixed Fire Suppression systems provided shall be in accordance with:

NFPA 12-Standard on Carbon Dioxide Extinguishing Systems
NFPA 12A - Standard on Halon 1301 Fire Extinguishing Systems
NFPA 17 – Standard for Dry Chemical Extinguishing Systems
NFPA 17A – Standard for Wet Chemical Extinguishing Systems
NFPA 2001 - Standard on Clean Agent Fire Extinguishing Systems

Any alterations or amendments to the submitted drawings will render this approval invalid.